



# Department of Building and Fire Prevention

4701 West Russell Road • Las Vegas NV 89118  
Building Division (702) 455-3000 • Fire Prevention Division (702) 455-7316

Jerome A. Stueve, P.E., Director/Building Official  
Samuel D. Palmer, P.E., Assistant Director • Girard W. Page, Fire Marshal

June 12, 2018

## FABRICATOR PROJECT SPECIFIC APPROVAL FAB-00461

Cimolai S.p.A. (Polcenigo Shop) has requested a project specific approval for the below listed project. Clark County has reviewed the fabricators application and documents in accordance with Technical Guideline 1 & 2.

PROJECT: Clark County - BD18-16374  
5617 Dean Martin Drive, Las Vegas, NV 89118  
Las Vegas Stadium  
Fabrication of secondary steel for the roof at the Las Vegas Stadium

FABRICATOR APPROVALS: Steel, Structural Steel

1. This project specific approval is valid for the project noted above. This project specific approval is granted based on the fabricators current fabrication facility certification(s). A project site visit inspection by the Clark County Department of Building and Fire Prevention(CCDB) and/or Jurisdictional Building Authority may be performed on the supplied fabricated components to verify workmanship requirements.
2. The fabricator is responsible, under this approval type, to comply with the CCDB requirement regarding Nondestructive Testing (NDT) of Full Penetration Welds. CCDB requires all full penetration welds on primary structural members with a material thickness of 5/16" and greater shall have a volumetric (Ultrasonic or Radiograph) NDT inspection performed by a CCDB approved agency, to ensure weld soundness.
3. The fabricator is responsible to provide a certificate of compliance to the project owner and contractor.

This approval is in accordance with Clark County Building Administrative Code Sections 22.02.535 Approved Fabricator/Manufacturer.

If you have any questions please contact David A. Chancey at (702) 455-2883 or email at [dac@clarkcountynv.gov](mailto:dac@clarkcountynv.gov).

### BOARD OF COUNTY COMMISSIONERS

STEVE SISOLAK, Chairman • CHRIS GIUNCHIGLIANI, Vice Chairman  
SUSAN BRAGER • LARRY BROWN • JAMES B. GIBSON • MARILYN KIRKPATRICK • LAWRENCE WEEKLY  
YOLANDA T. KING, County Manager



# Department of Building and Fire Prevention

4701 West Russell Road • Las Vegas NV 89118  
Building Division (702) 455-3000 • Fire Prevention Division (702) 455-7316

Jerome A. Stueve, P.E., Director/Building Official  
Samuel D. Palmer, P.E., Assistant Director • Girard W. Page, Fire Marshal

June 11, 2018

## FABRICATOR PROJECT SPECIFIC APPROVAL FAB-00460

Cimolai S.p.A. (Roveredo Shop) has requested a project specific approval for the below listed project. Clark County has reviewed the fabricators application and documents in accordance with Technical Guideline 1 & 2.

PROJECT: Clark County - BD18-16374  
5617 Dean Martin Drive, Las Vegas, NV 89118  
Las Vegas Stadium Project  
Fabrication of secondary steel for the roof at Las Vegas Stadium project

FABRICATOR APPROVALS: Steel, Structural Steel

1. This project specific approval is valid for the project noted above. This project specific approval is granted based on the fabricators current fabrication facility certification(s). A project site visit inspection by the Clark County Department of Building and Fire Prevention(CCDB) and/or Jurisdictional Building Authority may be performed on the supplied fabricated components to verify workmanship requirements.
2. The fabricator is responsible, under this approval type, to comply with the CCDB requirement regarding Nondestructive Testing (NDT) of Full Penetration Welds. CCDB requires all full penetration welds on primary structural members with a material thickness of 5/16" and greater shall have a volumetric (Ultrasonic or Radiograph) NDT inspection performed by a CCDB approved agency, to ensure weld soundness.
3. The fabricator is responsible to provide a certificate of compliance to the project owner and contractor.

This approval is in accordance with Clark County Building Administrative Code Sections 22.02.535 Approved Fabricator/Manufacturer.

If you have any questions please contact David A. Chancey at (702) 455-2883 or email at [dac@clarkcountynv.gov](mailto:dac@clarkcountynv.gov).

### BOARD OF COUNTY COMMISSIONERS

STEVE SISOLAK, Chairman • CHRIS GIUNCHIGLIANI, Vice Chairman  
SUSAN BRAGER • LARRY BROWN • JAMES B. GIBSON • MARILYN KIRKPATRICK • LAWRENCE WEEKLY  
YOLANDA T. KING, County Manager